

Village of Suttons Bay Staff Report December 2009

Water and Sewer Department:

Meters have been read
December Samples taken and results have come back Non Detection
January Samples Scheduled for the 7th
Pumpage usage reports started
Cross Connection reports started
Meter monitoring
Multiple meter removals
Minor repairs made at the Port Sutton Well House
Snow has been blown from Fire Hydrants
Bay View meter removals and shut offs
I prepared water and sewer system capacity/general information regarding master plan for Heather from LIAA.
Pressure issues have been investigated at certain parts of Port Sutton and adjusted accordingly.
Hydrant at Ice rink is being checked daily
Pump #1 at the Village Lift Station was pulled and adjustments made to shorten the distance between the impeller and volute cover.
Meter troubleshooting for a local business
Leak Detections and Inspections
Assisted Loren and Dave with the Clarifier cover installation
Organized tools for water and sewer departments and built custom shelving for the GMC
Service line froze and broke on South Shore, assisted the plumber and home owner locate leaks and shut water off at curb.

The rest of my time is spent with daily rounds and inspections, assisting the Streets Department with snow plowing/sidewalks and the WWTP on Mondays. Thanks to the guys for covering the departments during my week of vacation, I really appreciated it.

Ben Hursh
Sewer and Water Supervisor

Miss Digs.....1 Work Orders.....9
Call in.....3 Turn On/Off.....5

