

VILLAGE OF SUTTONS BAY
WASTEWATER TREATMENT PLANT
STAFF REPORT

December 1, 2009 through December 30, 2009

MONTHLY PERMIT COMPLIANCE:

The treatment plant met all discharge parameters during the month of November. Thus far through December all discharge parameters have been met pending final lab results for Biochemical Oxygen Demand.

FOLLOWUP ITEMS:

- Both UV light modules are still performing well enough to give us near perfect results.
- The clarifier cover framework was completed on December 3. The shrink wrap was placed on December 10. This year we used a heavier wrap material. The cover is working well thus far.
- No SCADA system failures during this reporting period.

NEW ITEMS:

- DNR Fish Biologists and Maintenance Mechanics from the State of Michigan Platte River Fish Hatchery visited the treatment plant to gain an understanding of our chemical feed system. They are having problems with phosphorous removal and the MDEQ suggested they contact us to gather information on our switch from alum to ferric chloride.

OTHER ITEMS:

- Snow removal.

Respectfully submitted,

Dave Goen, Superintendent
Village of Suttons Bay Wastewater Treatment